SOUTHWEST RESEARCH INSTITUTE®

Chemistry and Chemical Engineering Division Fire Technology Department San Antonio, Texas (210) 522-2638 Fax (210) 522-4518

Southwest Research Institute (SwRI) is an independent, nonprofit research and development organization founded in 1947 to support industry, business and government.

The manufacturer whose name appears below is qualified under the Listing, Labeling, and Follow-up Inspection Services Program established by SwRI as furnishing Flameshield[®] fire resistant aboveground storage tanks. The manufacturer is therefore authorized to use this document as proof of its compliance. Such representation certifies that the product under this Program is manufactured in compliance with the requirements established by SwRI for this product.

DOCUMENT NO.: SwRI Reference No. 00077-01/100-01

PRODUCT: Flameshield®

MANUFACTURED BY: Participating members of the Steel Tank Institute

LOCATION: North America

APPLICATION: Representative samples have been tested under SwRI Project No. 01-2632 in

accordance with procedures and guidelines as shown on the label below.

LABEL MARK: The Label Mark shown below is the only one authorized for application to this product.





SwRI is an Accredited Testing Laboratory and Inspection Agency by International Accreditation Service (IAS)

SwRI's QMS is Registered by NSF International Strategic Registrations (ISR)



Serial No. FS xxxx

FLAMESHIELD® SwRI I.D. 00077-01/100-01

- · Follow installation instructions.
- Tank is intended for stationary installation.
- Pressurize the primary tank when pressure testing the annular space of double wall tanks.
- This tank is built in accordance with UL 142.
- This tank is Listed to SwRI 97-04 to withstand a 2000°F fire for 2 hours without failure of the primary tank or supporting structure, or impairment of the venting system.