



| MARK | REQ'D. | SIZE | TYPE | REMARKS |
|------|--------|------|------|-----------------|
| G | 1 | 24" | FNPT | OPTIONAL MANWAY |
| F | 1 | 4" | FNPT | |
| E | 1 | 4" | FNPT | |
| D | 1 | 10" | RFSO | PRI E-VENT |
| C | 1 | 4" | FNPT | |
| B | 1 | 4" | FNPT | |
| A | 1 | 4" | FNPT | |

FITTING SCHEDULE

DESIGN: FABRICATED PER UL-142 SPECIFICATIONS SINGLE WALL CONSTRUCTION

INSPECTION: MODERN WELDING COMPANY
 MATERIAL: MILD CARBON STEEL (UNLESS NOTED)
 (INTERNAL): SURFACE PREP - CLEAN OF DEBRIS
 COATING - N/A
 (EXTERNAL): SURFACE PREP - SSPC-SP6 (COM BLAST)
 COATING - WHITE EPOXY

GENERAL NOTES

| SIZE | O.D. | LENGTH | APPROX. WEIGHT |
|--------|------|--------|----------------|
| 30,000 | 126" | 46'-6" | 21,000# |

THIS DRAWING IS FOR ILLUSTRATION PURPOSES ONLY AND IS NO TO BE RELIED UPON FOR ANY OTHER PURPOSE. NO WARRANTY OF MERCHANTABILITY, OF FITNESS FOR A PARTICULAR PURPOSE OR OF ANY OTHER KIND, EXPRESSED OF IMPLIED, IS HEREBY MADE.

 MODERN WELDING COMPANY, INC.

UL-142 SINGLE WALL AST
 TANK NOM CAPACITY: 30,000 GALLONS

| | | | |
|---------|-------------|---------------|------------|
| DWN BY: | SCALE: NONE | DATE: | DWG NUMBER |
| APR BY: | JOB NO: | SHEET: 1 of 1 | |