



2009-06-29

Modern Welding Co Inc
Po Box 1450
Owensboro, KY 42302
United States

Reference: File MH28465 Project 02ME15582

Subject: UL Listed Design 1, Model KW Series Gravity Feed Oil/Water Separators from Kleerwater Technologies, LLC

To Whom It May Concern:

This confirms that Underwriters Laboratories Inc. tested samples of the subject oil/water separators and that the results of the performance testing indicated oil effluent concentrations of less than 5 ppm.

Each UL Listed Oil/Water Separator shall be marked with the oil effluent rating (in ppm) for the corresponding influent oil rating (in ppm) and maximum flow rate.

The basic requirements used to investigate products in this category are Subject 2215, Outline of Investigation for Oil/Water Separators.

Please contact me if you have any questions.

Sincerely,

Tim Crews

Tim Crews
Staff Engineer
Department: 3009DNBK
Tel: 847-664-2516
Fax: 847-313-2516
E-mail: timothy.a.crews@usul.com