



333 Pfingsten Road
Northbrook, Illinois 60062-2096
United States Country Code (1)
(847) 272-8800
FAX No. (847) 272-8129
<http://www.ul.com>

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 210302-MH3217
ISSUE DATE: March 21, 2002



Issued to: Modern Welding Company
Box 1450
Owensboro, KY 42302-1450

Report Reference: MH3217


This is to Certify that representative samples of: "Glasteel" GS-58 Composite Underground Tanks for Flammable and Combustible Liquids.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL1746, External Corrosion Protection Systems for Steel Underground Storage Tanks; UL58 Steel Underground Tanks for Flammable and Combustible Liquids.


Additional Information: These are horizontal cylindrical tanks designed for underground storage of flammable liquids at atmospheric pressure. The tanks covered by this certificate consist of a steel core (single wall) covered with an external fiberglass-reinforced plastic (FRP) cladding which provides corrosion protection. The tanks are intended to be installed in accordance with the manufacturers instructions and the Flammable and Combustible Liquids Code - NFPA30, A copy of the manufacturers installation instructions accompany each tank.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: 
John Silsdorf
Underwriters Laboratories Inc.

Review Engineer: 
Wayne Doversberger
Underwriters Laboratories Inc.