

Certificate of Compliance

Certificate Number 20030505-MH19415
Report Reference 1999-12-27
Issue Date 2003 May 5

Page 1 of 1



Issued to: **Modern Welding Company**
P.O. Box 1450
Owensboro, KY 42302-1450


This is to certify that representative samples of **Series FR-58**
Coated Underground Tanks for Flammable Liquids (single wall)

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1746, External Corrosion Protection Systems for Steel Underground Storage
UL 58, Steel Underground tanks for Flammable and Combustible Liquids

Additional Information: These are cylindrical horizontal tanks for underground storage of flammable liquids at atmospheric pressure. They are fabricated by coating a UL 58 tank with a polyurethane coating. The coating is a two part mix that combines to become the FibreThane or the FibreThane Plus (Corrocote Plus) coating. The tanks are to be installed in accordance with the manufacturer's instructions and NFPA 30, Flammable and Combustible Liquid Code

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product