

Certificate of Compliance

Certificate Number 20030505-MH3217

Report Reference 1990-05-30

Issue Date 2003 May 5

Page 1 of 1



Issued to: **Modern Welding Company**
P.O. Box 1450
Owensboro, KY 42302-1450

This is to certify that representative samples of

Glasteel, GS-10 and GS-19 Series, Type II
Secondary Containment Composite Underground Tanks for Flammable Liquids

Intended to be installed in accordance with the mfgs. instructions and NFPA 30, Flammable and Combustible Liquid Code. A copy of the mfgs. instructions provided with tank.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 1746, External Corrosion Protection Systems for Steel Underground Storage
UL 58, Steel Underground Tanks for Flammable and Combustible Liquids.

Additional Information:

These horizontal cylindrical tanks designed for the underground storage of flammable and combustible liquids at atmospheric pressure. The tanks covered by this certificate consist of a steel core completely contained (full 360 degree) within a steel secondary containment that is physically separated from the primary core. They are provided with an external fiberglass-reinforced plastic (FRP) cladding for corrosion protection. The tanks have provision for monitoring leakage in the annular space between the primary steel core and the steel secondary containment.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:

 with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product