

MARK	REQ'D.	SIZE	TYPE	REMARKS
H	1	2"	FNPT	
G	1	2"	FNPT	
F	1	6"	FNPT	SEC E-VENT
E	1	4"	FNPT	PRI E-VENT
D	1	2"	FNPT	
C	1	2"	FNPT	
B	1	4"	FNPT	
A	1	2"	FNPT	MONITOR


FITTING SCHEDULE

DESIGN: FABRICATED PER UL-142 SPECIFICATIONS
 DOUBLE WALL CONSTRUCTION, 360° WRAP
 OPENINGS ARE THREADED TANK FLANGES,
 (P): INDICATES PRIMARY PENETRATION
 (S): INDICATES SECONDARY PENETRATION

INSPECTION: MODERN WELDING COMPANY
 MATERIAL: MILD CARBON STEEL (UNLESS NOTED)
 (INTERNAL): SURFACE PREP - CLEAN OF DEBRIS
 COATING - N/A
 (EXTERNAL): SURFACE PREP - SSPC-SP6 (COM BLAST)
 COATING - WHITE EPOXY

OPERATING PRESSURE: ATMOSPHERIC
 PRESSURE TEST: 3-5 PSI

GENERAL NOTES

SIZE	O.D.	LENGTH	APPROX. WEIGHT
560	48"	6'-6"	1,800#
THIS DRAWING IS FOR ILLUSTRATION PURPOSES ONLY AND IS NO TO BE RELIED UPON FOR ANY OTHER PURPOSE. NO WARRANTY OF MERCHANTABILITY, OF FITNESS FOR A PARTICULAR PURPOSE OR OF ANY OTHER KIND, EXPRESSED OF IMPLIED, IS HEREBY MADE.			
 MODERN WELDING COMPANY, INC.			
UL-142 DOUBLE WALL AST TANK NOM CAPACITY: 560 GALLONS			
DWN BY:	SCALE: NONE	DATE:	DWG NUMBER
APR BY:	JOB NO:	SHEET: 1 of 1	